

UNDERGROUND STORAGE TANK(S)

SITE NAME:

PTIA - Fire Station

REGULATED

NONREGULATED

☒

YES

NO

RELEASE CONFIRMED:

          

           ☒

CLEAN-UP INITIATED:

          

          

TANK(S) REMOVED:

           ☒

          

RELEASE UNDER CONTROL:

          

          

CLEAN-UP COMPLETED:

           ☒

          

TECHNICIAN:

W. B. G.

DATE:

6/3/53

Airport Fire Station

☒ USGS MAP

☒ BASE MAP

☒ ORIENTATION OF UST

6' LENGTH OF UST

48" DIAMETER OF UST

550 VOLUME OF UST

heat oil MATERIAL STORED

☒ SAMPLE LOCATIONS

8' DEPTH OF SAMPLE

floor SIDE OR FLOOR SAMPLE

2' DEPTH OF TANK BURIAL

backhoe HOW SAMPLE WAS COLLECTED

no preservation SAMPLES PRESERVED AND TRANSPORTED w/in 10 min. of collection

by lab TOOLS DECONTAMINATED

12/13 11:40 TIME/DATE SAMPLE COLLECTED

12/13 11:50 TIME/DATE LAB RECEIVED

<10 LAB RESULTS

3550 ANALYSIS METHOD

☒ C.O.C.

☒ REFERENCE TO SAMPLING POINT ON MAP

1 CORRECT # OF SAMPLES

Y WITHIN 14 DAYS HOLDING TIME FOR SAMPLES

Safeway TANK DESTINATION

NA DISPOSITION OF SOIL

12-11-90 REMOVAL DATE

NA COMPLETE GW/UST-2 FORM